



NOTES

1. IF A GREATER VOLUME OF WATER FLOW IS DESIRED, EITHER:
 - A) SUBSTITUTE OVAL TRANSITE PIPE FOR THE ROUND PIPE; THE VERTICAL HEIGHT OF THE OVAL PIPE SHALL NOT EXCEED FOUR (4) INCHES; OR,
 - B) CONSTRUCT A MODIFIED NUMBER 12 BOX CULVERT.
2. IF A PIPE DRAIN IS INSTALLED THROUGH A CURB WITH LESS THAN A NOMINAL EIGHT (8) INCH FACE, THE FLOW LINE OF THE PIPE SHALL BE AT THE SAME ELEVATION AS THE FLOW LINE OF THE GUTTER. SUCH PIPE SHALL NOT EXCEED THREE (3) INCH NOMINAL DIAMETER.
3. COUNTY CLASS "B" (5 1/2 SACK/YD., 3/4" MAXIMUM AGGREGATE), CONCRETE SHALL BE USED FOR REPOURING THE CURB
4. FOR INSPECTION CALL DEPARTMENT OF PUBLIC WORKS AT 310-378-0383.

APPROVED FOR CONSTRUCTION		STANDARD CURB DRAIN City of Palos Verdes Estates P.V.E. STD. PLAN ST-40
CITY ENGINEER	RCE NO. C049632	
LAST REVISION DATE		
MAY 15, 2000		